Industrial Services

TÜVRheinland®
Precisely Right.

Attn.: Mr. Joydeep Bose
EB Air Control Inc.
6185, Tomken Road Unit #1-2
Mississauga, ON, L5T 1X6

Jul 31, 2025

Confirmation of Type Testing

TUV Reference #: 00015072025-01
Type of Equipment: 67 Dampers
Model Designation: IPSD
Test Requirements: EN 12266-:2012 and EN 12266-2 (with deviations)
Totally 5 pages including this cover sheet

Dear Mr. Joydeep Bose,

I hereby confirm that the following tests have been carried out on the dampers listed in the appendix I

1. Shell Strength/Tightness, test P10/P11 in accordance with EN 12266-1:2012
2. Back seat tightness, test P21 in accordance with EN 12266-2:2012
3. Opening and Closing times

All tests are witnessed with satisfactory results. See attached report for detail.

If i can be of any further assistance, please do not hesitate to call upon me.

Sincerely,

Marco-Jörg Wilm
M. Eng./ IWE
Head of I.01 Hamburg / Hildesheim / Bremen
Pressure Equipment & Plant Engineering
TUV Rheinland Industrial Service.

TUV Rheinland Industrial Service GmbH
Julius-Vosseler-Straße 42
22527 Hamburg
Germany

Cell Phone: +49 172 3272174

Mail: Marco-joerg.wilm@tuv.com

Web: www.tuv.com

Member of
TÜV Rheinland Group